

**DECLARATION OF CONFORMITY**

In compliance with EU Regulation (EU): No 305/2011 of March 2011, Construction Product Regulation (CPR):

Unique identification code of the product-type:

**FloPlast Fire Protection Collar FC55, FC82, FC110 & 160**

Intended use or uses of the product, in accordance with the applicable harmonised standards and EU directives:

**Penetration seals to prevent the spread of fire through PVC, HDPE & PP pipes where they penetrate fire compartment walls and floors.**

Name and contact address of supplier:

**FloPlast Limited,  
Castle Road,  
Eurolink Business Park,  
Sittingbourne,  
Kent.  
ME10 3FP  
United Kingdom**

System or systems of assessment and verification of constancy of performance of the construction product as set on in ETA 16/0056:

**System 1**

Covered by harmonised standard:

**ETA 16/0556**

Declared performances:

Essential characteristics	Performance	Harmonised technical specification
Reaction to fire	<b>ETA 16/0556</b>	<b>ETAG 26-02 (Used as EAD)</b>
Resistance to Fire		
Dangerous substances		

The information with this Conformity CE Certificate was first issued on 10/08/16

The performance of the product identified is in conformity with declared performances.

This declaration of performance is issued under the sole responsibility of the supplier.

Neil Harrison



QESH Manager

FloPlast Ltd

Date: 10<sup>th</sup> June 2017

Place of Signing: Sittingbourne Kent